

12th Annual Groundwater Quality Workshop

4040 Paramount Boulevard
Lakewood, CA 90712

August 9, 2017 (9:30AM ~ 2:30PM)

Speaker #1

WRD Overview – August 2017

Brian Partington

Water Replenishment District

bpartington@wrd.org





Overview - August 2017

Brian Partington, PG, CHg

August 9, 2017

9:30 – 10:00

WRD Overview

Brian Partington, WRD

10:00 – 10:30

DDW Regulatory Updates

Jeff O-Keefe, SWRCB - DDW

10:30 – 11:00

Well Profiling Tool to Identify Zones of Contamination in Water Supply Wells

Noah Heller, BESST Inc.

11:00 – 11:30

Designing and Implementing a Multi-Facility SCADA System in the Age of Information

Phuong Ly, WRD; Luke Stephenson & Chris Schleich, Enterprise Automation

11:30 – 12:00

Ex-Situ Groundwater Remediation Options for Perchlorate

Steve Winners, WorleyParsons Advisian

Cathy Swanson, Evoqua Water Technologies, LLC.

12:00 – 12:45

Lunch provided by WorleyParsons

The screenshot shows the WorleyParsons website homepage. At the top left is the company logo with the tagline "resources & energy". To the right is the "EcoNomics" logo and the text "ASX Share Price: WOR" followed by a search bar. A navigation menu includes "Home | Site Map | Contacts | Privacy Policy". Below this is a secondary menu with "About Us", "Global Presence", "Customer Sectors", "Consulting", "Project Delivery", and "Investor Relations". The main content area features a large image of an industrial site with a blue crane. A blue overlay on the image contains the text "INFRASTRUCTURE" and "Complete infrastructure solutions for resource, energy and urban markets including environment and restoration; water, rail and port assets; power generation and network". To the right of the image is a "Careers" section with the text "Join our team of passionate professionals" and a "NEWS" section with a headline "7 Jul 17 - Exclusive PhD studentship on offer with Imperial College London" and a "READ MORE" link. At the bottom right is a "Webcast" section for "Investor Day 2017" with a "READ MORE" link. The company logo is visible in the bottom right corner of the page.

12:45 – 1:15

UCMR4 Implementation Strategies for Water Systems

Rick Zimmer, Eurofins Eaton Analytical

1:15 – 1:45

Principles of Efficient Water Well Design

Kevin McGillicuddy, Roscoe Moss Company

1:45 – 2:15

Groundwater Basins Master Plan

Everett Ferguson, WRD

2:15 – 2:30

Questions and Certificates

The presentations will be emailed to the participants and/or uploaded to <http://www.wrd.org>





- **History and Mission**
- **Major Programs**
- **Resources and Online Programs**
- **Water Independence Now**

Past History:

1900s-1950s

Pumping Double Natural
Replenishment.

OVERDRAFT



**100 foot
drop in
10 years
(10'/yr)**

- **Plunging Water Levels**
- **Loss of Supply**
- **Wells going Dry**
- **Seawater Intrusion**

- **WRD formed in 1959 to eliminate overdraft via Managed Aquifer Recharge (MAR).**
- **Pumping adjudicated at 281,835 acre feet/year (AFY).**
- **Higher than natural recharge within the basin, but the difference is made up WRD.**



**SERVICE AREA =
420 SQUARE MILES**



43 CITIES



**POPULATION
> 4 MILLION**



**550,000 ACRE FEET
USED PER YEAR**



**50% GROUNDWATER
FROM LOCAL WATER
WELLS**



50% IMPORTED WATER



**WRD SUPPLEMENTS
NATURAL GROUNDWATER
RECHARGE**



**SECURING OUR
WATER FUTURE TODAY**

4040 Paramount Boulevard | Lakewood, California 90712



@waterreplenish



facebook.com/waterreplenishment





youtube.com/waterreplenishment



www.wrd.org

Over 400 Wells Provide Water Supply



HOW WRD MANAGES THE BASINS

REPLENISHMENT OF GROUNDWATER




GROUNDWATER CLEAN UP




BASIN MONITORING



BASIN MODELING



Replenishment Facilities



LA County Public Works Recharge Facilities



Injection Wells



Spreading Grounds




Injection Wells





Spreading Grounds



Replenishing Groundwater Basin




Results of WRD Basin Management



Rising water levels & drought protection

Forecasted water levels during drought without recharge



Regional Groundwater Monitoring Program


Sampling



Nested Monitoring Wells




Drilling with USGS



Data Presented in Two Annual Reports



**Water Replenishment District
of Southern California**




**Engineering Survey
and Report**





2015

March 5, 2015

Updated:
May 1, 2015




Water Replenishment District
of Southern California



**REGIONAL GROUNDWATER MONITORING REPORT
WATER YEAR 2013-2014**

Central and West Coast Basins
Los Angeles County, California

February 2015



Interactive Well Search



http://gis.wrd.org/wrdmap/index.asp
WRD Interactive Well Search

File Edit View Favorites Tools Help
Suggested Sites

Interactive Well Search

[NEW SEARCH](#)
[WRD HOME](#)
[HELP](#)
[LOGOUT](#)

- Zoom In
- Zoom Out
- Full Extent
- Pan Map
- Select Well
- Select by Rectangle
- Select by Polygon
- Select by Circle
- Clear Selection
- Measure Distance
- Set Units
- Print Map
- View Map Legend
- Toggle Overview

Select Wells to Report On


REPORTWRD ID	State #	County #	Map Label	Common Name	Well Owner	Well Type	Well Status
<input type="radio"/>	102241	UNK	Vern1_1	Vern1_1	Water Replenishment District of Southern California	Barrier Observation Well	Active
<input type="radio"/>	102242	UNK	Vern1_2	Vern1_2	Water Replenishment District of Southern California	Barrier Observation Well	Active
<input type="radio"/>	102243	UNK	Vern1_3	Vern1_3	Water Replenishment District of Southern California	Barrier Observation Well	Active
<input type="radio"/>	102244	UNK	Vern2_1	Vern2_1	Water Replenishment District of Southern California	Barrier Observation Well	Active
<input type="radio"/>	102245	UNK	Vern2_2	Vern2_2	Water Replenishment District of Southern California	Barrier Observation Well	Active
<input type="radio"/>	102246	UNK	Vern2_3	Vern2_3	Water Replenishment District of Southern California	Barrier Observation Well	Active
<input type="radio"/>	102247	UNK	Vern3_1	Vern3_1	Water Replenishment District of Southern California	Barrier Observation Well	Active
<input type="radio"/>	102248	UNK	Vern3_2	Vern3_2	Water Replenishment District of Southern California	Barrier Observation Well	Active

Tools

Print Table

Map Results

Interactive Well Search



WRD Interactive Well Search - Microsoft Internet Explorer provided by WRD

http://gis.wrd.org/wrdmap/index.asp

File Edit View Favorites Tools Help

WRD Interactive Well Search Well Reports

NEW SEARCH WRD HOME HELP LOGOUT

Constituents: Total Dissolved Solids (TDS)

Print Table

Date	Concentration Level	Units
11/19/1998	630	mg/l
5/12/1999	540	mg/l
9/22/1999		mg/l
5/3/2000		mg/l
10/10/2000		
5/21/2001		
2/13/2002		
11/4/2002		
6/23/2003		
4/8/2004		
9/9/2004		
3/8/2005		
9/13/2005		
3/17/2006		mg/l
8/30/2006		mg/l
4/11/2007		mg/l
9/11/2007		mg/l
4/2/2008		mg/l
9/2/2008		mg/l
3/30/2009	394	mg/l
8/19/2009	360	mg/L
3/11/2010	370	mg/L

WRD WELL: 100033

Well Construction

Water Level

Well Production

Water Quality

Map Search


New Search

100030 4S/13W-09H09S UNK 9H9 CAR1_1 Water Replenishment District Monitoring Well Active

WRD currently updating the Interactive Well Search Tool.

Account requests at <http://gis.wrd.org/wrdmap/login.asp>


Well Profiling Program



Contact Charlene King at cking@wrd.org (562.275.4252)

Safe Drinking Water Program (since 1991)

- Financial assistance for wellhead treatment.
- Outreach program for DACs.



Contact Charlene King at cking@wrd.org (562.275.4252)

Groundwater Contamination Program

- **WRD staff track the progress of high priority environmental investigations located in the West Coast Basin and Central Basin (currently 48).**
- **Conduct high level reviews and when necessary provide feedback to the various regulatory agencies including EPA, DTSC, RWQCB.**

WRD awarded \$7.28M in Proposition 1 grant funds to cleanup a Perchlorate and VOC “hot spot” in the City of Vernon (March 30, 2017).

Contact Brian Partington at bpartington@wrd.org (562.275.4249)

**COLLECTION OF PROJECTS
TO ELIMINATE REMAINING
DEMAND FOR IMPORTED WATER**

A key to developing independence from imported water is the development of local recycled water sources.



WATER INDEPENDENCE NOW

PROJECTS TO:



**CAPTURE AND CONSERVE
ADDITIONAL STORMWATER**



**INCREASE USE OF RECYCLED
WATER FOR GROUNDWATER
REPLENISHMENT**



GOAL IS TO REPLACE IMPORTED WATER WITH LOCALLY AVAILABLE WATER (E.G. RECYCLED WATER) FOR AQUIFER REPLENISHMENT.




BENEFITS OF RECYCLED WATER OVER IMPORTED WATER:




INCREASED RELIABILITY



COST-EFFECTIVE



LOCALLY CONTROLLED



DROUGHT PROOF

**SECURING OUR
WATER FUTURE TODAY**

4040 Paramount Boulevard | Lakewood, California 90712

 @waterreplish
 facebook.com/waterreplishment
 youtube.com/waterreplishment

 www.wrd.org

**GRIP IS THE CORNERSTONE
OF WRD'S WIN PROGRAM**



GROUNDWATER RELIABILITY
IMPROVEMENT PROJECT



**GRIP WILL PROVIDE 21,000 ACRE-FEET PER YEAR
OF RECYCLED WATER IN PLACE OF EXPENSIVE
IMPORTED WATER.**



**UPON COMPLETION, GROUNDWATER BASINS
WILL BE COMPLETELY LOCALLY SUSTAINABLE**

**SECURING OUR
WATER FUTURE TODAY**

 [@waterreplish](https://twitter.com/waterreplish)
 facebook.com/waterreplenishment
 youtube.com/waterreplenishment

 www.wrd.org



Operations
& Learning Center

Process Facility

**SECURING OUR
WATER FUTURE TODAY**

4040 Paramount Boulevard | Lakewood, California 90712



@waterreplish

facebook.com/waterreplishment

youtube.com/waterreplishment



www.wrd.org



WATER REPLENISHMENT DISTRICT
OF SOUTHERN CALIFORNIA

Thank You!

Brian Partington

bpartington@wrd.org

562.275.4249



GROUNDWATER RELIABILITY
IMPROVEMENT PROJECT



WATER INDEPENDENCE NOW

Speaker #2

DDW Regulatory Update

Jeff O'Keefe

SWRCB - DDW

Jeff.okeefe@waterboards.ca.gov



California Drinking Water Program Regulatory Update

WRD Groundwater Quality Workshop

August 9, 2017

Jeff O'Keefe, P.E., Chief
Southern California Coast Section
Southern California Field Operations Branch
SWRCB – Division of Drinking Water

Presentation Outline

1. 1,2,3-TCP Maximum Contaminant Level (MCL)
2. Hexavalent Chromium MCL Removal
3. Lead and Copper – Recent Developments
4. Revised Total Coliform Rule
5. Perchlorate MCL Revision
6. Potable Reuse of Recycled Water
7. ELAP Regulations
8. Cross-Connection Control regulations

California's Division of Drinking Water

- Northern California Field Operations Branch
- Southern California Field Operations Branch
- Program Management Branch

- Technical Operations Section
- Environmental Laboratory Accreditation Program (ELAP)
- Quality Assurance Section - **NEW**

District Offices and LPAs:

- 7500+ Water Systems
- 5 Regions
- 24 State District Offices
- 30 County Local Primacy Agencies



1,2,3-TCP Maximum Contaminant Level (1,2,3-Trichloropropane)

- Synthetic organic chemical (SOC)
 - Industrial solvent, degreaser
 - Ingredient in soil fumigants widely used for many decades
- Public Health Goal (PHG) established 2009
 - 0.7 ppt (parts per trillion)
 - Possible carcinogen
- **MCL adopted by Board on July 18, 2017**
 - **5 ppt (DLR also 5 ppt)**
- GAC is a best available technology

1,2,3-TCP Maximum Contaminant Level


- Regulation will be effective October 2, 2017
- Initial monitoring period begins January 1, 2018
 - 4 quarterly samples
- Compliance determination
 - For PWS serving >3,300 population, compliance based on initial, confirmation sample(s), and 6 monthly samples
 - For PWS serving <3,300 population, compliance based annual average of initial, confirmation sample(s), and quarterly samples
- Grandfathering of previous monitoring
 - Results collected within two calendar years of effective date
 - Substituted for same quarter of initial period
 - 2nd quarter 2016 for 2nd quarter 2018
 - Only substitute 3 of 4 required initial samples
 - Request must be in writing to DDW

1,2,3-TCP Maximum Contaminant Level

- 2001-2015 Occurrence Data:
 - **471 wells with confirmed detections above 5 parts per trillion (ppt)**
 - Range of Detections: **5 ppt to >10,000 ppt**
- Vast majority of detections in groundwater
 - Most in Central Valley (Kern, Fresno, Tulare counties)
 - Riverside – 25 sources
 - San Bernardino - 31 sources
 - Los Angeles – 58 sources

1,2,3-TCP Occurrence Data

County	# of known sources	County	# of known sources
BUTTE	1	SAN BERNARDINO	31
FRESNO	90	SAN DIEGO	6
KERN	117	SAN JOAQUIN	20
LOS ANGELES	58	SAN LUIS OBISPO	3
MADERA	2	SAN MATEO	7
MENDOCINO	1	SANTA CLARA	1
MERCED	31	SANTA CRUZ	3
MONO	1	SOLANO	1
MONTEREY	4	STANISLAUS	19
RIVERSIDE	25	TULARE	49
SACRAMENTO	1		



Google earth

Data SIO, NOAA, U.S. Navy, NGA, GEBCO
 Image Landsat
 © 2015 Google
 Data LDEO-Columbia, NSF, NOAA

Hexavalent Chromium (Cr 6)

- On May 31, 2017, the Superior Court of Sacramento County invalidated the Cr 6 MCL stating the regulator did not adequately document the economic feasibility of complying with the MCL
- On August 1, 2017 the State Board adopted a resolution to remove the current Cr 6 MCL
- Staff will begin the process of having the regulatory text deleted, which should take effect in late September 2017, and develop a new standard as soon as possible

Lead and Copper Rule – DDW Recommendations

- March 7, 2016, DDW sent a letter to all community and nontransient noncommunity water systems
- Recommendations on improving public access to Lead and Copper Rule (LCR) information
- Reminder to provide sample results to those participating in LCR tap sampling:
 - w/in 30 days of receiving the results from lab, and;
 - w/in 1-2 working days if lead and/or copper levels over the respective action levels are found

http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/leadandcopperrule.shtml

Lead in Drinking Water

- U.S. EPA is working to issue a **Revised Federal Lead & Copper Rule**
- EPA Resources on its Web Site
 - Basic Information about Lead in Drinking Water
 - Lead in Drinking Water at Schools and Child Care Facilities
 - 3Ts for Reducing Lead in Drinking Water in Schools
- State Board priority regulation
- **NEW** Electronic submittal of lead and copper tap sample results using Lab to State Portal
 - Training for laboratories provided on 6/20/2017, check with your certified lab

Lead Sampling in Schools

- Meetings with the Governors office and Department of Education throughout 2016 resulted in the decision for DDW to issue an amended permit to all community water systems who serve a K-12 school
- Permit requires water systems to sample at school (5 sample sites) when a school official makes a request in writing to the water system for sampling assistance
- **Permits issued January 17, 2017** along with a media release and resources on the DDW website (FAQs, details of sampling procedures, lab data submittals)


http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/leadsamplinginschools.shtml

Lead Sampling in Schools


- Schools can request sampling assistance anytime prior to November 1, 2019.
- As of July 21, 2017, a total of 1,201 schools have provided a copy of their request letter to the Division, and 981 schools have submitted results
- Schools will be responsible for corrective actions (removing/replacing drinking fountains, POU devices, etc.)
- Drinking Water for Schools Grant Program
 - \$9.5 M available, serving small DACs

School Requests and Results Received

Number of School Requests as of July 21, 2017
Lead Sampling in California Schools



Number of Results Received as of July 21, 2017
Lead Sampling in California Schools



Lead Service Lines: Requirements of SB 1398

- All public water systems must compile an inventory of known lead service lines by July 1, 2018
- PWS must also identify areas that may have lead service lines and identify any areas where the PWS cannot identify the service line material
- By July 1, 2020, PWS will be required to propose a schedule to replace all the known lead service and service lines constructed of unknown material
- SB-427 has been introduced to change and clarify - the requirement should only apply to community water systems (bill is still in committee)
- DDW will have a web portal available in Fall 2017 to begin receiving documents for the water system's inventory.
- FAQs, guidance and updates available on DDW website

http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/lead_service_line_inventory_pws.shtml

Revised Total Coliform Rule

- Federal RTCR effective April 1, 2016
- Interim Period before state adoption
 - All PWS must comply with existing CA rule and Federal RTCR
- CA regulation in development and anticipated in 2018
 - Draft regulation available on DDW website

Revised Total Coliform Rule

- Overall approach is to “Find and Fix” problems
- Minor changes to routine and repeat sampling
 - No changes to # of samples per week or month
 - 3 repeat samples for each TC+ routine
 - Existing location, U/S and D/S within 5 service conn.
 - PWS collecting 1 routine/month, 4 repeats still needed
- Established E.coli MCL
 - EC+ Routine, TC+ Repeat
 - TC+ Routine, EC+ Repeat
 - EC+ Routine, no repeats collected
 - TC+ Routine, fail to analyze for E.coli
- Established Coliform Treatment Technique

Revised Total Coliform Rule

Level 1 Coliform Treatment Technique

- Triggers when:
 - > 5% of samples TC+, if collecting 40 or more samples/month
 - 2 or more samples TC+, if collecting fewer than 40 samples/month
 - Failure to collect all repeats following TC+ routine
- Water system must complete Level 1 assessment and make corrective actions within 30 days
- **Issue Tier 2 public notice** within 30 days
 - **INTERIM PERIOD ONLY**

Revised Total Coliform Rule

Level 2 Coliform Treatment Technique

- Triggers when:
 - E. Coli MCL violation
 - Second Level 1 trigger within a 12-month period
- Issue Tier 1 Public Notice by end of day
- Contact DDW (or LPA) by end of day
- DDW (or LPA) staff will conduct Level 2 assessment and water system must complete and make corrective actions within 30 days

Revised Total Coliform Rule

- Failure to conduct the Level 1 or Level 2 assessments within 30 days or failure to complete corrective actions is a violation requiring a Tier 2 Public Notice
- New requirements for seasonal water systems to follow approved start-up protocol including sampling before serving water to the public

http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/rtcr.shtml

Perchlorate MCL Revision

- Current MCL 6 ug/L is greater than revised Public Health Goal of 1 ug/L (2015).
- Current Detection Level for Reporting (DLR) is 4 ug/L.
- July 5 Board meeting decision to initiate two-step process for revising perchlorate MCL
 1. Amend Title 22 regulations to lower DLR
 2. Gather occurrence data below 4 ug/L for use in considering a revised perchlorate MCL

Potable Reuse of Recycled Water

- **Groundwater Recharge** is “the planned use of recycled water for replenishment of a groundwater basin or an aquifer that has been designated as a source of water supply for a public water system”
- **Surface Water Augmentation** is “the planned placement of recycled water into a surface water reservoir used as a source of domestic drinking water supply”
- **Direct Potable Reuse** is “the planned introduction of recycled water either directly into a public water system, as defined in Section 116275 of the Health and Safety Code, or into a raw water supply immediately upstream of a water treatment plant”

Potable Reuse - Statutory Requirements

Task	Deadline	Status
Adopt Groundwater Recharge Regulations	Dec 31, 2013	
Adopt Surface Water Augmentation Regulations	Dec 31, 2016	Moving quickly
Prepare Draft Report on Expert Panel Recommendations & Research Status	June 30, 2016	
Release Public Review Draft Report on Feasibility of Developing Direct Potable Reuse Criteria	Sept 1, 2016	
Submit Final Report to the Legislature	Dec 31, 2016	

Surface Water Augmentation Regulations

- GW recharge regulations built over 38 years experience
- **Key components**
 - Pathogen reduction requirements – reclamation plant + Surface Water Treatment Plant (SWTP)
 - Reservoir criteria, meaningful environmental buffer
 - Wastewater source control
 - Full advanced treatment (RO + advanced oxidation)
 - Monitoring for regulated & unregulated chemicals
- Public Hearing Sept 7, comment period closes Sept 12, 2017
- 0 approved SWA projects in CA; 3 SWA projects in planning

Direct Potable Reuse - Feasibility

- **Public health is most important**
- Expert Panel & Advisory Group
- Research needs & knowledge gaps
- Lessons learned from other projects
- Crafting effective criteria
- Deliberate and phased approach



Environmental Laboratory Accreditation Program (ELAP)

- Preliminary draft regulations released on 7/24/2017 and six stakeholder workshops were held statewide from 7/25/2017 to 8/3/2017
- Comments can be submitted by email to elapca_comments@waterboards.ca.gov
Use subject line: ELAP Preliminary Draft Regulations Comments
- Board adoption expected in 2018



Cross-Connection Control Regulations

- Work on updating these regulations, which are currently in CCR Title 17, is anticipated to begin soon

Questions?

Jeff O'Keefe

Jeff.okeefe@waterboards.ca.gov

(818) 551-2068

Speaker #3

Well Profiling Tool to Identify Zones of Contamination in Water Supply Wells

Noah Heller

BESST Inc.

nheller@besstinc.com



Selective Groundwater Extraction

Profiling Groundwater Production Wells and Temporary Long Screened Test Wells For Zonal Flow, Zonal Water Chemistry

By

Noah Heller, MS PG (CA 5792)
President, BESST, Inc.
50 Tiburon Street, Suite 7
San Rafael, CA 94901
Office: 415.453.2501
Mobile: 415.302.7354
nheller@besstinc.com





Flow and Water Chemistry Profiling

Basic Purpose Historically: To Understand Zonal Flow and Water Chemistry into Well

Why?: Lost Production and Water Quality Problems

Historical Well Profile Frequency – Rare (1970-2006)

Why? Cost, Relatively New Idea, Not enough institutional and market sector knowledge

GOALS

- AVOID TREATMENT
- MINIMIZE TREATMENT
- UNDERSTAND STRATIFICATION OF CONTAMINANTS IN WATER RESOURCE AQUIFERS
- USE GEOCHEMICAL STRTIFICATION DATA TO SELECT TEST HOLE LOCATIONS FOR NEW WELLS
- USE IN LONG SCREENED, TEMPORARY TEST WELLS TO INCREASE DATA DENSITY (AVOID WATER QUALITY FAILURES FOR NEW WELLS)
- SUPPORT FOCUSED WELL REHABILITATION (BEFORE AND AFTER PERFORMANCE METRIC – ZONAL SPECIFIC CAPACITY)



U.S. Geological Survey Combined Well-Bore Flow and Depth-Dependent Water Sampler

The U.S. Geological Survey has developed a combined well-bore flow and depth-dependent sample collection tool. It is suitable for use in existing production wells having limited access and clearances as small as 1 inch. The combination of well-bore flow and depth-dependent water-quality data is especially effective in assessing changes in aquifer properties and water quality with depth. These are direct measures of changes in well yield and ground-water quality with depth under actual operating conditions. Combinations of other geophysical tools capable of making these measurements, such as vertical-axis current meters used with wire-line samplers, are commercially available but these tools are large and can not easily enter existing production wells.

BASIC OPERATING PRINCIPLES

The U.S. Geological Survey device is a high-pressure hose equipped with valves for dye injection and sample collection. The hose is mounted on a reel for deployment, retrieval, and storage (fig. 1). The hose can be used to collect velocity-log data and, after cleaning and decontamination, the same hose can be used to collect depth-dependent water-quality data. Accessories, such as a Teflon® hose extension, are available for collection of organic compounds.

Velocity-Log Data

The equipment is used to obtain flow data within the well bore under pumping conditions using a technique we named the "tracer-pulse method." When operated in this mode, the hose is filled with fluid containing an easily measured tracer, such as water colored with Rhodamine dye. The hose is lowered to a known depth in the well (d_1) and a pulse of the tracer is injected into the water column. The travel-time of the tracer to a detector on the surface is measured (t_1). If Rhodamine dye is used, a commercially available fluorimeter is used to measure the arrival




Figure 1. Example of typical deployment in a deep-turbine production well.

of the dye at the surface. The hose is then lowered to the next depth (d_2), another pulse of dye is released, and the travel-time is measured (t_2). The velocity is calculated as the difference in the travel-times. Assuming piston flow, the flow rate (Q), given a known well radius (r), is calculated using the following equation:

$$Q = (V\pi r^2) \text{ where } V = (d_2 - d_1) / (t_2 - t_1)$$

A series of injections at different depths is done to construct a velocity profile for the well. The velocity profile can then be used to guide the collection and interpretation of depth-dependent water-quality data.

Depth-Dependent Water-Quality Data
To collect a water-quality sample from a given depth in the well, the hose is pressurized to greater than the hydrostatic pressure at that depth and lowered into the well. When the sample depth is reached, the hose is vented at the surface and water from the well at the sample depth enters the hose. The hose is retrieved and the sample expelled from the hose under pressure. The process is repeated at several depths to complete a water-quality profile within the well. If the concentrations of a constituent at the first sample depth (C_1) and the second sample depth (C_2) are known, the concentration in water entering the well from the intervening water-bearing zone (C_d) can be calculated from the water-quality profile and the velocity-log data:

$$[(C_1)(Q_1 - C_2)(Q_2)(Q_d)] = C_d$$

where $Q_d = (Q_1 - Q_2)$

This calculation assumes conservative mixing and conservation of mass.

APPLICATIONS

The data shown in figure 2 are from a deep production well in a complex multiple-aquifer system. These data illustrate changes with time in the chloride concentration of water entering the well at depth and changes with time in the distribution of flow into the well. Because changes in well yield and water quality measured at the surface were small, these changes would not have been detected using conventional sample collection methods which are a composite of all the water flowing into the well. A comparison of data from a velocity log using a conventional spinner tool and a velocity log using the tracer-pulse method also is shown in figure 2. The tracer-pulse method correctly identified the most important water-yielding zone and the depth below which almost no water enters the well. Neither of these important hydrologic features could have been identified on the basis of indirect data, such as a resistivity log (fig. 2).

The combination of velocity-log data and depth-dependent water-quality data is an especially effective data set for hydrologic interpretations. Specific applications for data collected using this approach include:

- (1) Identification of changes in ground-water quality and well yield with time.
- (2) Identification of different water-bearing units with depth.




Figure 2. Example of depth-dependent flow and chemical data sampled from a deep production well.

- (3) Identification of changes in natural ground-water chemistry with depth.
- (4) Identification of man-made or natural contaminants with depth.

Although the applications described here


are primarily for production wells, the approach also can be applied to observation wells. This approach may be especially useful to assess the performance of wells used for remediation if contaminants are stratified within the aquifer.

- Dr. John Izbicki
- Over 90 Peer Reviewed Articles
- Recipient of California Groundwater Resources Association Lifetime Achievement Award
- Inventor of Dye Tracer

2005-2017: BESST Selective Groundwater Extraction Database California

● = 1 – 10 Production Wells Profiled by BESST


- >700 Municipal Production Wells Profiled Since 2005
- Largest Stratified, Dissolved Aqueous Phase Geochemistry Data Base in California for Production Wells



How Has Miniaturization Changed Frequency of Well Profiling Groundwater Production Wells?


Single Diameter Well		
Technology: Spinner Log Survey	Low	High
Remove Pump	\$8,000	\$ 12,000.00
Install and Rent Test Pump with Access Pipe	\$30,000	\$ 80,000.00
Perform Spinner Log Survey	\$3,000	\$ 5,000.00
Perform Water Sampling Survey (5 to 8 Samples)	\$4,000	\$ 6,000.00
Reinstall Pump	\$8,000	\$ 12,000.00
Consulting Planning. Workplan, Field Fees	\$12,000	\$ 20,000.00
Consulting Fee	\$10,000	\$ 20,000.00
Total	\$75,000	\$ 155,000.00
Single or Telescoping Well		
Technology: Straddle Packer Survey		
Remove Pump	\$8,000	\$ 12,000.00
Install Straddle Packer (3 to 5 Zone Tests)	\$90,000	\$ 150,000.00
Perform Spinner Log Survey	\$0	\$0
Perform Water Sampling Survey (5 to 6 Samples)	\$0	\$0
Reinstall Pump	\$8,000	\$ 12,000.00
Consulting Planning. Workplan, Field Fees	\$12,000	\$ 20,000.00
Consulting Fee	\$10,000	\$ 20,000.00
Total	\$128,000	\$ 214,000.00
Technology: Miniaturized Tracer / Water Samp.		
Remove Pump	\$ -	\$ 12,000.00
Install Straddle Packer (3 to 5 Zone Tests)	\$ -	\$ -
Perform Spinner Log Survey	\$ -	\$ -
Perform Water Sampling Survey (5 to 6 Samples)	\$ -	\$ -
Perform Tracer / Water Sampling Survey	\$ 25,000.00	\$ 35,000.00
Reinstall Pump	\$ 8,000.00	\$ 12,000.00
Consulting Planning. Workplan, Field Fees	\$ 5,000.00	\$ 10,000.00
Consulting Fee	\$ 5,000.00	\$ 10,000.00
Total	\$ 43,000.00	\$ 79,000.00

COST versus Technology Apparatus Size versus Rate of Groundwater Profiling Growth




As profiling tools get smaller and wells more accessible, profiling cost decreases

Well Access and Incrementally Tiered Access Survey





Vent Tubes, Bolt Holes, Plug Holes, Existing Sounding Pipes



Pump Pedestal (Block) Coring



First core hole attempt on north side of 20 inch well (with 14" bowls) found less than $\frac{3}{4}$ " annular clearance with pump column.



Core hole was drilled at 5 Degree angle from vertical and at 1.5" in diameter.

Portable drill is adjustable to various angles and is mounted directly to pedestal.



Pedestal Core



Elliptical Piece of Metal From Outer Casing generated from steep angle core hole.



Core Hole # 2 was successful and found 5+ inches of annulus on south side of well.



Approximate drill time for each of the core holes (1st attempt north side of well and 2nd attempt (successful) on south side of well) was 2.5 hours per hole. Coring cost was about \$125 / hr. The core hole was temporarily lined with a section of PVC pipe to protect the tracer hose from scraping and tearing against any rough surfaces within the hole.

Lift and Shift


No Access Pipe(s)



Remove Primary Pump and Reinstall Primary Pump With Access Pipe(s)

Well Screen above Pump Scenario

If the primary pump and the intake are located within the well screen then alternate strategy can be taken by installing two access pipes as shown in Figure 2 below.



Access Pipe Layout with Bottom End Cone Flare

Riser Pipe Requirements:

Either


- 1) 1.25" ID x 1.66" OD
- 2) 1.00" ID x 1.31" OD

And,

- 3) Flush threaded PVC above bowls
- 4) Flush threaded stainless steel along Bowls and extending 10' feet past bowls.
- 5) Flared, smoothed, rounded of bottom.

Optional:

- 6) Client can used galvanized steel pipe with couplings provided there is enough annular space.



Remove Primary Pump and Reinstall With Test Pump and Access Pipe(s)

Access Pipe Installation

Assuming that the position of the primary pump is located above the well screen, the bottom of the access pipe should extend at least 10 feet below the pump intake and still be above the well screen.

The access pipe should be secured firmly to the pump column at intervals to prevent movement of the pipe as shown in the following examples.



Figure 2: Riser banded to pump bowls



Figure 3: Stainless Steel Pipe attached to pump

The access pipe should terminate above the wellhead, and should be smoothed as well to prevent snagging of tools or sampling tubing.

Brief Description of Conventional Technologies

Straddle Packer


Spinner

Tracer Technology





**Flow and Water Chemistry
Profiling are volumetric and
chemical mass balance
accounting systems**

**Think about a river with blue ping
pong balls!**





FLOW FROM well
To Fluorometer





Fluorometer

Flow From Fluorometer To Waste

Explanation of Dye Injection Process For Dynamic Flow Profiling In Production Wells

Cumulative Flow Slices (CFS)



Dynamic Flow Profile Under Steady State Draw-Down

Dye Injection Shot Points

Ft. Below Ground Surface

- 40
- 60
- 80
- 100
- 120
- 140
- 160
- 180
- 200
- 220
- 240
- 260
- 280
- 300
- 320
- 340
- 360
- 380
- 400

Cumulative Flow Can Be Defined As

$$Q_1 = V_1 \times A_1$$



$$V_1 = (d_1 - d_2) / (t_1 - t_2)$$

$$A_1 = \pi r^2$$

Incremental Flow Can Be Defined As

$$Q_1 - Q_2$$



When we subtract Q_2 from Q_1 , we get the incremental flow (IF or GPM) contribution between the two measured injection points



Average Cumulative Contaminant Concentration Can Be Defined As

$$Ca_1 = (Q_1 C_1 - Q_2 C_2) / (Q_1 - Q_2)$$

Incremental Average Contaminant Concentration between two imaginary flow planes within the well can be expressed



Dynamic Groundwater Sampling Under Steady State Draw-Down

Groundwater Sampling Points

Ft. Below Ground Surface	Cumulative Concentration
40	Ca ₁
60	Ca ₂
80	Ca ₃
100	Ca ₄
120	Ca ₅
140	Ca ₆
160	Ca ₇
180	Ca ₈
200	Ca ₉
220	Ca ₁₀
240	Ca ₁₁
260	Ca ₁₂
280	Ca ₁₃
300	Ca ₁₄
320	Ca ₁₅
340	Ca ₁₆
360	Ca ₁₇
380	
400	




No Contaminant Contribution

No Contaminant Contribution

Houston Metro Area Well

Well Information	Diameter	GPM	Ft. BGS
Total Depth			1230
Pump Intake Depth			550
Pumping Water Level*			356
Pumping Rate *		1000	
Casing Schedule			
Blank	20		0-724
Blank	14		650-730
Perforated	14		730-800
Blank	14		800-850
Perforated	14		850-858
Blank	14		858-908
Perforated	14		908-916
Blank	14		916-966
Perforated	14		966-972
Blank	14		972-980
Perforated	14		980-1004
Blank	14		1004-1024
Perforated	14		1024-1042
Blank	14		1042-1078
Perforated	14		1078-1110
Blank	14		1110-1136
Perforated	14		1136-1170
Blank	14		1170-1194
Perforated	14		1194-1210
Blank	14		1210-1230

*At the time of testing




KEY	
	Sandy Clay
	Clay
	Gray Sand
	Gray Sand
	Loose Sand
	Blue Clay


Gross Alpha

Well Head Average: 8.6 pCi/L

Total Flow: 1000 GPM





Lithologic Log (1950)



City Yard Well Information and Lithology Log


Well Information

- Old (outside) well casing diameter: 20" -> 14"
- Outside screened Intervals (ft. bgs): (290-330), (390-410), (480-570), (620-720), (780-830), (880-970), (1000-1020), (1070-1190)
- New well casing diameter: 16" -> 12" -> 10"
 - New well casing is constructed with all stainless steel wire wrap.
- New pump column diameter (in): 10" (16" casing)
- Cross sectional area of new well casing:
 - From 0'-282': 1.40 ft²
 - From 282'-786': 0.79 ft²
 - From 786'-1206': 0.55 ft²
- Reported new well bottom: 1190 ft. bgs
- Pump Intake Depth: 230 ft bgs
- Pumping water level: 143 ft bgs
- Flow rate: 1860 USG min⁻¹



Dynamic Flow Profile 1860 gpm 11/19/13


Zonal Flow Contribution (GPM)




Chemistry Profile

1860 gpm 11/20/13


Average Chloride Well Head Concentration: 15 mg/L



Well Zonal Production %
Chloride Concentration mg/l
MCL 500. mg/l



Zonal Production GPM
Chloride Concentration mg/l
MCL 500. mg/l




2 Field Days
To collect data

Chemistry Profile

1860 gpm 11/20/13


Average Sulfate Well Head Concentration: 43 mg/L



Chemistry Profile


1860 gpm 11/20/13

Average TDS Well Head Concentration: 270 mg/L




Well Zonal Production %
TDS Concentration mg/l
MCL 1000. mg/l

0.00 200.00 400.00 600.00



Zonal Production GPM
TDS Concentration mg/l
MCL 1000. mg/l

0.00 200.00 400.00 600.00




Chemistry Profile


1860 gpm 11/20/13

Average Arsenic Well Head Concentration: **12.5** $\mu\text{g/L}$

Well Zonal Production % (Green)
Arsenic Concentration $\mu\text{g/l}$ (Blue)
MCL 10. $\mu\text{g/l}$






Zonal Production GPM (Green)
Arsenic Concentration $\mu\text{g/l}$ (Blue)
MCL 10 $\mu\text{g/l}$



Chemistry Profile

1860 gpm 11/20/13


Average Iron Well Head Concentration: 145 µg/L



Chemistry Profile

1860 gpm 11/20/13

Average Manganese Well Head Concentration: **64** µg/L



Well Reconstruction / Re-Engineering

How Do We Hydraulically Manipulate Groundwater Production Wells?

- Change Pumping Rate
 - Higher Pumping Rate Vertically Shifts Flow Contribution Downward Inside Well – Away From Pump Intake
 - Lower Pumping Rate Vertically Shifts Flow Contribution Upward Inside Well – Towards Pump Intake

- Change Pump Intake Location and/or Diameter
 - Lower or Raise Pump (Intake)
 - Attach Suction Pipe To Bottom of Pump

- Packers, Sleeves and Engineered Suctions

- Focused Well Rehabilitation
 - Remove Mineral Encrustations and Bio-film on Inside and Outside of Well Screen


● Change Pumping Rate




Example #1



Dynamic Tracer Pulse Flow Meter Survey @ 1,200 GPM / 11/08/07



Dynamic Spinner Log Flow Meter Survey @ 2,166 GPM / 04/29/05




**Comparison of BESST Dynamic Tracer Pulse Flow Survey with Spinner Log Flow Meter Survey:
 Performed At Different Pumping Rates and At Different Times**

Example #2



Comparison of BESST Dynamic Tracer Pulse Flow Survey with Spinner Log Flow Meter Survey:

Performed At Different Pumping Rates and At Different Times




Flow Rate Difference Between Surveys:
 3,500 GPM Spinner
 -1,900 GPM Dye
 992 GPM

Example #3




Dynamic Tracer Pulse Flow Meter
Survey @ 2,600 GPM / 04/24/08


Dynamic Spinner Log Flow Meter
Survey @ 3,004 GPM / 04/18/06





Change Pump Intake Location
Change Pump Intake Diameter



 Pump Depth Location From Top Of 16" Well Screen

32.25 feet
Below Top Of Well Screen




FIG. 4. Entrance Velocity Profile with Pump Intake Located 32.25 ft into Well Screen

43.75 feet
Below Top Of Well Screen
Lowest Entrance Velocities
Least Drawdown (Head Loss)





FIG. 5. Entrance Velocity Profile with Pump Intake Located 43.75 ft into Well Screen

67.85 feet
Below Top of Well Screen




FIG. 6. Entrance Velocity Profile with Pump Intake Located 67.85 ft into Well Screen




FIG. 7. Total Drawdown as Function of Pump Intake Location in Well Screen




FIG. 8. Entrance Velocity Profile for Different Intake Diameters





FIG. 9. Total Drawdown as Function of Pump Intake Diameter

greatest uniformity of entrance velocity, the cost becomes pro-

- Packers, Sleeves and Engineered Suctions

Packer Case History



Well #26 Geologic Log


and BESST Dynamic Flow Contribution Profile


(2/11/2010)

BESST Dynamic Flow Profile

Pumping Rate: 849 GPM **Pumping Water Level:** 340'


Screen Interval: 655-715, 745-785, 825-870, 890-920, 960-1010, 1075-1190





As	Sample Depth (ft bgs)	Screen Interval (ft bgs)	Cumulative Flow Per Screen Interval (GPM)	Incremental Flow Per Screen Interval	As Measured Concentration (From Lab)	CnQn	CnQn-Cn+1Qn+1	Incremental Flow	Mass Balance As Incremental Concentration	Predicted Discharge Average
	600	655-715	849.00	97.00	19.50	16555.5	11.5	97.00	0.12	11.5
	730	745-785	752.00	188.00	22.00	16544.0	1880.0	188.00	10.00	1880
	805	825-870	564.00	268.00	26.00	14664.0	7856.0	268.00	29.31	7856
	880	890-920	296.00	14.00	23.00	6808.0	322.0	14.00	23.00	322
	940	960-1010	282.00	97.00	23.00	6486.0	4266.0	97.00	43.98	4266
	1055	1075-1190	185.00	185.00	12.00	2220.0	2220.0	185.00	12.00	2220
								849.00		
								100%		
Spigot 1	Cumulative		849.00		19.00					16555.5
Spigot 2	Cumulative		849.00		19.00					19.50

Dynamic Chemical Profile: Well 26
2/11/10 849 GPM
Arsenic




Well 26: Estimated Arsenic Distribution By Screen Interval Blocking Off 3 rd , 4 th and 5 th Screen From Top Of Well										Predicted Discharge Average
Sample Depth	Screen Interval	Cumulative Flow Per Screen Interval	Incremental Flow Per Screen Interval	Measured Concentration (From Lab)	CnQn	CnQn- Cn+1Qn+1	Incremental Flow	Mass Balance Incremental Concentration		
600	655-715	470.00	97.00	19.50	16555.5	11.5	97.00	0.12	11.5	
730	745-785	373.00	188.00	22.00	16544.0	1880.0	188.00	10.00	1880	
805	825-870	0.00	0.00	0.00	14664.0	7856.0	0.00	0.00	0	
880	890-920	0.00	0.00	0.00	6808.0	322.0	0.00	0.00	0	
940	960-1010	0.00	0.00	0.00	6486.0	4266.0	0.00	0.00	0	
1055	1075-1190	185.00	185.00	12.00	2220.0	2220.0	185.00	12.00	2220	
							470.00	GPM		
							55%	of 849 GPM		
Spigot 1	Cumulative	470.00		8.75						4111.5
Spigot 2	Cumulative	470.00		8.75						8.75

The hypothetical scenario presented represents a worse case scenario in terms of estimated maximum production loss from well. Feasibility testing is recommended to determine hydraulic compensation yield from unblocked zones.




Dynamic Arsenic Profile: Well 26


849 GPM



Packer Test Scenario




Packer Test Scenario



Potential Strategies for a Feasibility Test:

Goal: To Produce Less Arsenic at Discharge and Hydraulically Compensate for Groundwater Production Lost From Blocked Zones (red)

Well #26: Arsenic Reduction Profile




Before Modification

US EPA MCL = 10 ug/l

Solution For "Synergistic Well Modification"

Side Stream Treatment



Tools of the Trade: Swage



Hydraulic Swage



Drive Swage



Hydraulic Swage, ready for use



Casing Patch



Swaging & Patching



Hydraulic Swage




Hydraulic Swage ready to set a casing patch

- Focused Well Rehabilitation



Total GPM = 950





BEFORE AND AFTER REHAB WELL PROFILING

One of the least used performance metrics


Before and After Well Profiling

Rehab Performance Metrics

Pre-Rehabilitation

S.C. 17.4
Q 700 gpm
Eff. 62%
Mn 75 ug/L

Zone of High Manganese Production



Post-Rehabilitation

S.C. 22.6
Q 850 gpm
Eff. 72%
Mn < 20 ug/L

Cement/Bentonite Cap


Gravel Fill Material

Zonal Profiling During or After Pump Tests

Rules, Recommendations and Insights:

1. Zonal flow profiling assumes dynamic steady state condition.
2. Can be performed during or following pump test.
3. If performed following pump test, then dynamic profile must be performed at same pumping rate as pump test.
4. Use of zonal profiling during or following pump test provides estimate of hydraulic conductivity.
5. Can be performed with primary pump or test pump.
6. Recommend that pump intake depths are the same when dynamic zonal test is performed following pump test.
7. Estimates may be skewed in wells lacking recent rehab; however data may still be very useful on a relative basis and provide clues concerning sections of gravel pack clogging.

Using Pump Test and Zonal Flow Results To Calculate Estimated Zonal Hydraulic Conductivity From Production Wells



$$\frac{K_{FM,i}}{\bar{K}} = \frac{\Delta Q_i / Q_p}{\Delta b_i / B}$$

Molz et. al 1989 and 1994

\bar{K} = Average hydraulic conductivity from well pump test

Q_p = Average pumping rate from well


B = Screened thickness of aquifer

ΔQ_i = Discharge measured within the i -th sampling interval of vertical thickness Δb_i

$K_{FM,i}$ = Estimated value for the hydraulic conductivity representative of the i -th vertical interval

Compelling Application:


Well Field Design, Expansion, Management




Standard Exploration Test Method Options



Method 1
Drill Stem
Test Well



Method 2
PVC Test Well



Seals
Electric Submersible Pump

- **Drill Rig Can Never Leave Site**
- Expensive: funding typically enough for ONLY 3 to 5 zones
- More time and difficult to develop
- More time and costly to abandon
- Drill String could become buried (method 1)
- Bentonite seal may leak



Exploratory Borehole




Total Depth


**Expensive Data
Deficiencies**

Run
Geophysics

SP Resistivity
eV Ohm meters




**Zone Testing 6 to 24 Hours Per Zone
Using Sequential Backfill Method
Determine Pumping Rate For Each Test?
Zone Selections are COARSIFIED!!!**



Profiling Temporary Long Screened Wells with BESST Tracer Technology


Electric Submersible

Multiple Pump Intake Locations: Each pump intake depth – pumped at dynamic, steady state conditions




Long Screened Test Well

Advance Borehole and Log Cuttings




Run Geophysics




Spontaneous Potential eV


Resistivity Ohm m



Identify Injection and Sampling Depths



Construct Long Screened Well Build Well Screen Intervals






Construct Long Screened Well
Gravel Pack and Seals (tremmied)

Drilling Rig Demobs From Site

Pump Rig Mobs Onto Site

Develop Well: Remove Mud
Cake and Drilling Fluid w/
Electric Submersible Pump




Pump Development Location 1

GOAL = 10 NTUs


Pump Development Location 2

Pump Development Location 3



Development

Zonal Flow Profile with Miniaturized USGS/BESST Tooling Of Long Screened Test Well



6 to 8 Inch Inside Diameter / 15 to 20 cm

- All Injections are performed one depth at a time
- All Tracer injection return times monitored with ground surface fluorometer connected to line tap
- All Injections are sideways to obtain most accurate flow rate inside long screened well
- Injections performed until no return from furthest tracer release depth
- Then, pump is raised to just below the furthest tracer return depth from pump depth location #1
- Packer below pump is inflated
- The second velocity, zonal flow profile is now performed from pump depth location #2

Speaker #4

Designing and Implementing a Multi-Facility SCADA System in the Age of Information

Phuong Watson

Water Replenishment District

pwatson@ wrd.org

Luke Stephenson

Enterprise Automation

Luke.Stephenson@eaintegrator.com

Chris Schleich

Enterprise Automation

Chris.Schleich@eaintegrator.com



Designing & Implementing a Multi-Facility SCADA System in the Age of Information


**WRD Groundwater Quality Workshop
August 9, 2017**

Agenda

- Purpose of the WRD SCADA Master Plan
- SCADA Master Plan Development
- Key WRD SCADA Projects
- Partnering with the Right Integrator
- Benefits of executing the WRD SCADA Master Plan
- Road Map to Success

SCADA Master Plan

- A SCADA System Master Plan was completed in May 2016
- Some key components:
 - Support the design of future facilities
 - Integration with existing facilities, including communications back to a centralized SCADA system
 - Network design and cybersecurity program
 - Develop & implement stds for software, hardware, graphics, programming, etc.
- Major challenges:
 - WRD is not an operating agency
 - Facilities constructed at different times with no standards in place
 - Construction projects in progress
 - Lack of internal staff with expertise



Key Objectives of SCADA Master Plan



Build consensus & determine future direction




Prioritize SCADA projects with useable budgets




Maximize investment in control system equipment



Retain SCADA system integrator (Enterprise Automation) to assist with integration of key WRD projects



SCADA Master Plan Dvlpt



Enterprise Automation




210



- **CSIA Certified Integrator (1 of 3 in SoCal)**
- **Schneider Electric's #1 Integrator in U.S.**
 - *SCADA Certified Alliance I.P. (1 of 1 in U.S.)*
 - *PlantStruxure Certified Alliance I.P. (1 of 1 in CA)*
- **Wonderware System Platform Certified (1 of 3 in SoCal)**



WRD System Overview



Central Information System (CIS)



- ◆ The CIS is being established at WRD's headquarters
- ◆ The CIS will be able to view, and eventually operate, all of WRD's facilities

Groundwater Reliability Improvement Program (GRIP) Advanced Water Treatment Facility (AWTF)

- By Summer 2018, the GRIP AWTF will be completed and have the ability to produce up to 21,000 AFY of advanced treated recycled water for recharge at the Montebello Forebay Spreading Grounds
- The current design requires coordination with the SCADA Master Plan



GROUNDWATER RELIABILITY
IMPROVEMENT PROJECT

Miles

Enterprise Asset Mngt System

ENTERPRISE ASSET MANAGEMENT SYSTEM

Development & Implementation

Centralized SCADA System (CIS)

Multiple Information Sources (CMMS, Document Mngt System, etc.)

SCADA
LVL
AWTF

SCADA
Goldsworthy
Desalter

SCADA
Turnout
Structures

SCADA
GRIP
AWTF

Groundwater
Monitoring
Wells

The Right Integration Partner



Long-term captive integrator (3+ years)



Qualified, based on the needs of the Master Plan




Partnership, behaves like an extension of staff



Participation, seeks to engage with you


Winning Formula

Right Plan + Right Partner = Incredible Value



**Long-term, qualified
partner who wants
to collaborate**

Introduction



World Class SCADA Benefits




Consistency

Consistency




Installed 2008




Installed 2012

Consistency



2009 - Filters System



2017 - HydroElec System

World Class SCADA Benefits




Consistency




Predictable


Predictable




Unreliable & Unvalid



Unreliable, But Valid



Reliable, Not Valid



Both Reliable & Valid

World Class SCADA Benefits



Consistency



Predictable



Documented / Traceable

Documented



World Class SCADA Benefits



Consistency



Predictable



Documented / Traceable



Secure



Skeptical? Good!

Road Map to Success



Client Involvement, both client and integrator need to be working together

1. Client Involvement - Workshops

Non-PTW individual startup sequence

Permissives (SDF-7 only)

- pump + valve in remote + SCADA Auto + in service
- no device alarms
- valve closed (SDF-7 only)

Initiation

- startup button (Plant config screen) + Remote (Well LCP)
- Start button + Local switch (Well LCP)
- Non-PTW group Startup sequence start command

PTW Shutdown

Initiation

- Shutdown button (Plant config screen) + Remote (Well LCP)
- Stop button + Local (Well LCP)
- Shutdown Alarms


Sequence

- ~~1. If PTW enable open waste valve to initial pos sp~~ *or recent PTW performed (PTW not required timer)*
2. Call pump, wait for pump control valve full open
- ~~3. Enable PTW FC loop~~
- ~~4. Start PTW timer~~
- ~~5. Wait for timer to expire + pH button~~
- ~~6. If in local, wait~~
- ~~7. If flow to plant enabled, proceed, else shutdown~~
- ~~8. Open production valve, wait for full open (SDF-7 only)~~
- ~~9. Disable waste FC loop~~
- ~~10. Close waste valve~~

SP / Commands

- PTW enable/disable
- Flow to plant enable/disable
- PTW timer
- TDS
- Chloride
- Sulfate
- Flight time (SDF-7)
- PTW not required timer
- Initial Waste valve position SP
- PTW flow SP

1. Remove pump call, wait for pump to stop or pump fail to stop or pump fail DI
2. Close production valve (SDF-7 only)
- ~~3. Disable FC loop~~
- ~~4. Close waste valve~~



Road Map to Success



Client Involvement, both client and integrator need to be working in concert




Document decisions and standards, otherwise things will change


2. Document Standards

Standards

“The way we do things around here...”



Control Panels



Servers,
Security,
Networking

Road Map to Success



Client Involvement, both client and integrator need to be working in concert




Document decisions and standards, otherwise things will change



Both sides need a champion, enforcement of decisions is key

3. Champions

HOW STANDARDS PROLIFERATE:
(SEE: A/C CHARGERS, CHARACTER ENCODINGS, INSTANT MESSAGING, ETC.)



Road Map to Success



Client Involvement, both client and integrator need to be working in concert



Document decisions and standards, otherwise things will change



Both sides need a champion, enforcement of decisions is key



Project execution

- Defined and Clear Estimate/Scope
- Written Specifications
- QC / Testing
- Real Project Management
- Early Planning



Thank You

For more information visit

www.wrd.org

www.EAintegrator.com

Speaker #5

Ex-Situ Groundwater Remediation Options for Perchlorate

Steve Winners

WorleyParsons (Advisian)

Steve.Winners@advisian.com

Cathy Swanson

Evoqua Water Technologies, Inc.

catherine.e.swanson@evoqua.com

EX-SITU GROUNDWATER REMEDIATION OPTIONS FOR PERCHLORATE

Water Replenishment District of Southern California

2017 Annual Groundwater Quality Workshop

August 9, 2017

SPEAKERS

Cathy Swanson, Evoqua

Ms. Swanson received her BS in Chemical Engineering from Northwestern University. Her experience includes, lab technician, facilities engineering, operations, technical service, marketing, account management, and most recently business development. She has spent the past 10 years focused on groundwater cleanup of inorganic constituents especially for drinking water.

Steve Winners, PE, WorleyParsons

Mr. Winners received his BS in Agricultural Engineering from Cal Poly San Luis Obispo. He is a Professional Civil Engineer in the State of California with 20+ years of environmental engineering experience working for two firms in Southern California. He has held both management and technical roles. He has assembled and participated in multi-disciplinary teams of geologists, hydrogeologists, geochemists, toxicologists, and engineers conducting assessment, remediation and management of chemical releases to groundwater.

AGENDA

PART 1

1. Perchlorate Chemistry
2. Natural Sources of Perchlorate
3. Perchlorate Use
4. Perchlorate In The Environment
5. Drinking Water Contaminant History
6. Human Health Considerations
7. Regulatory Update



PART 2

1. Technology Selection Factors
2. Information Needed To Design A System
3. Treatment Technologies Not Applicable to Perchlorate
4. Treatment Technologies Applicable to Perchlorate
5. Ion Exchange
6. Biological

PART 1



PERCHLORATE CHEMISTRY



- Fundamental physical and chemical nature complicates treatment.
- Perchlorate tetrahedron structure of four oxygen atoms surrounding the central chlorine atom.
- Effectively blocks reductants from directly attacking the chlorine.
- Thermodynamically a strong oxidizing agent but kinetically a sluggish species, such that its reduction is generally very slow, rendering common reductants ineffective.

Source: US EPA

NATURAL SOURCES OF PERCHLORATE

- Chilean nitrate deposits
 - Chief source of nitrogen for explosives, fertilizer, and chemical industries from the 1830s to the 1930s.
 - Only significant source of iodine from the 1870s (replacing seaweed) until the mid-20th century (when iodine began to be extracted from oilfield brines).
- New Mexico potash
- Canada potash
- California hanksite
- Bolivian playa (evaporative) crusts



PERCHLORATE USE

- Solid propellant for rockets, missiles, for the defense and aerospace industries.
- Primary oxidizer in matches, road flares, air bag initiators for vehicles, pyrotechnics, ordnance, and explosives.



PERCHLORATE IN THE ENVIRONMENT

- Soluble and very mobile in water systems.
- Resistance to reactions with other available water constituents.
- Can persist in the environment for many decades under typical groundwater and surface water conditions.



Source: US EPA

DRINKING WATER CONTAMINANT HISTORY

- Perchlorate was found to be a contaminant in drinking water supplies for the Western United States in 1997. The issue was triggered when elevated levels of perchlorate were discovered in California drinking water supplies using a new, more sensitive analytical method (US EPA Method 314.0 Determination of Perchlorate in Drinking Water Using Ion Chromatography).
- More recent occurrence studies have found perchlorate contamination in both groundwater and surface waters serving as drinking water sources for more than 16 million people in at least 26 states nationwide, though most often in the southwest.

Drinking water sources with perchlorate detections.											
County	Year initially detected									Total No. of Sources	Peak level (µg/L)
	1997	1998	1999	2000	2001	2002	2003	2004	2005		
Los Angeles	54	31	21	13	8	24	7	12	7	177	159
San Bernardino	31	1	1	8	34	8	3	4	5	95	820
Riverside	14	5	5	11	16	19	10	3	1	84	73
Orange	-	20	-	-	1	9	7	-	-	37	11
Sacramento	10	2	-	1	-	1	-	1	9	24	400
Tulare	-	-	-	2	11	1	-	-	-	14	24
Santa Clara	-	-	1	2	1	2	3	-	1	10	8.5
San Diego	-	-	-	-	1	-	-	4	-	5	7
Ventura	-	1	1	-	-	-	-	2	-	4	20
Imperial	-	-	-	-	3	1	-	-	-	4	6
Sonoma	-	-	-	1	-	-	-	-	-	1	5
Stanislaus	-	-	-	-	-	-	1	-	-	1	3.3
TOTAL	109	60	29	38	75	65	31	26	23	456	-

Source: State of California

HUMAN HEALTH CONSIDERATIONS

- Perchlorate is classified as a goitrogen by the United States Environmental Protection Agency (US EPA), because at high levels it can interfere with the thyroid's ability to uptake iodide and thus affect hormone production.
- Thyroid hormones play a vital role in the growth and development of the central nervous system of fetuses and infants.
- According to the National Research Council, pregnant women, infants, children, and people with iodine-deficient diets or preexisting thyroid deficiencies may be more sensitive to perchlorate than the general population.

Source: Water Research Foundation

REGULATORY UPDATE

Source:



- **US EPA** anticipated proposing an MCL but does not currently regulate perchlorate in drinking water.
- **California** and Massachusetts currently regulate Perchlorate in drinking water with maximum contaminant levels (**MCLs**) at **6 µg/L** and **1 µg/L**.
- California established an MCL for perchlorate 2007 based on a Public Health Goal (PHG) of 6 µg/L.
- California reduced the PHG from 6 µg/L to 1 µg/L in 2015.
- **California** previously set the detection limit for purposes of reporting (DLR) at 4 µg/L, and in July 2017 recommended **reducing the DLR** to a level closer to, equal to, or less than the PHG of **1 µg/L**.
- If supported by new data at a lower DLR, California **may lower the MCL** to as close to the **1 µg/L PHG** as is **technologically and economically feasible**.

PART 2



TECHNOLOGY SELECTION FACTORS

- **Water Quality Factors**

- Perchlorate and co-contaminant concentrations
- Geochemical and other water quality parameters
- Indigenous Perchlorate-Reducing Microbes (PRM) and substances that inhibit PRM.

- **Water Quantity Factors**

- Groundwater Remediation (10-100 gpm)
- Groundwater Production (1,000-10,000 gpm)

- **Waste Disposition Considerations**

- Brine discharge pipelines and permit
- Liability of generator

- **End Use Considerations**

- Direct domestic use
- Groundwater recharge
- Recycled water use
- Storm drain or surface water discharge
- Publicly owned treatment works (POTW) discharge

INFORMATION NEEDED TO DESIGN A SYSTEM

Description
Operational Flow Rate
Operational Schedule
Daily Volume (average)
Perchlorate
Chloride
Nitrate (as NO ₃)
Sulfate
Alkalinity (as CaCO ₃)
pH
TDS

TREATMENT TECHNOLOGIES **NOT** APPLICABLE TO PERCHLORATE



- **Standard Granular Activated Carbon (GAC)**
 - Designed to sorb contaminant to a solid
 - Perchlorate has a high solubility and low affinity for sorption to solids
- **Air Stripping**
 - Designed to partition the contaminant from water to air phase
 - Perchlorate is non-volatile
- **Precipitation**
 - Perchlorate will not precipitate at any pH
- **Chemical Reduction**
 - Add a reagent to enhance contaminant degradation
 - Structure blocks reductants from directly attacking the chlorine.

Source: US EPA

TREATMENT TECHNOLOGIES

Most Common Approaches:

- Ion Exchange
 - Single-Pass
 - Regenerable
- Biological Reduction
 - Fluidized Bed Reactors
 - Fixed Bed Reactor
 - Continuously Stirred Reactor
 - Post-treatment required


Not Generally Used:

- Membrane Filtration
 - Reverse Osmosis – 25% waste stream to dispose of
- Tailored GAC
 - More expensive than resins
- Chemical Reduction
 - “Expensive and slow”
- Electrochemical Reduction
 - “Slow process”
- Electrodialysis


Source: US EPA

PRINCIPLES OF ION EXCHANGE

- Ion Exchange, or IX, is based on the principle of exchanging a harmless ion for the contaminant
- A reversible exchange of ions between a solid and a liquid in which there is no substantial change in the structure of the solid - the solid being the ion exchange resin.
- Example: $R-Cl + NH_4 ClO_4 \rightleftharpoons R-ClO_4 + NH_4 Cl$



ANION ION EXCHANGE – SELECTIVITY FOR A PERCHLORATE RESIN



REGENERABLE ION EXCHANGE

- Produces concentrated perchlorate waste brine which generally cannot go to sewer
- Perchlorate is not destroyed, so liability is not severed for the generator



SINGLE PASS ION EXCHANGE

- Most common treatment
- DDW listed best available technology
- Low carbon footprint
- Simple operations – generally runs 6 to 9 months until spent
- Perchlorate is destroyed if resin goes to Waste-to-Energy Facility for incineration where a Certificate of Destruction ends generator liability



SINGLE PASS RESIN SITE CONSIDERATIONS

- Compact design: Treat up to 2000 gpm in 420 sq ft (vessels only)
- Systems run in lead/lag because perchlorate is considered an acute toxin
- Prefiltration is recommended



BIOLOGICAL TREATMENT

- Types:
 - Fixed Bed Reactor
 - Fluidized Bed Reactor
 - Biocatalyst
 - Continuously Stirred Reactor
- Excellent choice when paired with high nitrate levels. Also, chrome VI, selenium
- Requires chemical feeds
- Must meet surface water treatment regulations with post filtration
- Limited number of drinking water applications in US as technology is just starting to gain acceptance



SOURCES OF INFORMATION

- **National Sources**
- United States Environmental Protection Agency (US EPA)
- American Water Works Association Research Foundation (AWWARF)
- Water Research Foundation (WRF)
- Ground-Water Remediation Technologies Analysis Center (GWTRAC)
- Interstate Technology & Regulatory Council (ITRC)
- **State Sources**
- California Environmental Protection Agency (Cal-EPA)
- California State Water Resources Control Board (SRWCB)

THANK YOU!

QUESTIONS?

Cathy Swanson
Catherine.E.Swanson@Evoqua.com
562-217-0419

Steve Winners
Steve.Winners@Advisian.com
714-920-8836

Speaker #6

UCMR4 Implementation Strategies for Water Systems

Rick Zimmer

Eurofins Eaton Analytical

RickZimmer@eurofinsUS.com






UCMR4 Implications & Strategies for water systems

August 9, 2017

Purpose of the UCMR



UCMR History



UCMR1

2001 2002 2003

UCMR2

2008 2009 2010

UCMR3

2013 2014 2015

UCMR4

2018 2019 2020

UCMR4 Schedule



2017	2018	2019	2020	2021
<p><i>After final rule publication:</i> EPA/state primacy authorities (1) develop SMPs (including the nationally representative sample); (2) inform PWSs/ establish monitoring plans; and (3) continuation of laboratory approval</p>	<p style="text-align: center;"> Assessment Monitoring List 1 Contaminants </p> <p style="text-align: center;"> <i>All large systems serving more than 10,000 people;</i> <i>800 small systems serving 10,000 or fewer people for cyanotoxins;</i> <i>800 small systems serving 10,000 or fewer people for the 20 additional contaminants.</i> </p> <p style="text-align: center;">Reporting and analysis of data</p>			<p>Complete reporting and analysis of data</p>


UCMR4 Monitoring Requirements



UCMR4 Requirement	Groundwater Systems	Surface Water and GWUDI Systems	Sample Location
Metals (2) Alcohols (3) Pesticides (9) Semivolatiles (3)	Two Times in 12-Month Period 5-7 Months Apart	Four Times in 12-Month Period 3 Months Apart	EPTDS
Brominated HAA groups (3)	Only Required if conducting DBP Stage 2 Monitoring		DBP Stage 2 HAA Compliance Point
DBP Indicators - TOC, Bromide (2)			Source Water
Total Microcystins (1) Microcystins, Nodularin (7) Anatoxin-a, Cylindrospermopsin (2)	Not Required	8 times (2 weeks apart) in 4-Month Period March - November	EPTDS

DBP Stage 2 Exemption = No DBPs or source monitoring
Consecutive Systems = No source monitoring

UCMR4 Sample Locations



UCMR4 Sample Locations - DBPs



Contaminant/ Disinfectant	Coverage		Stage 2 DBPR
	Source Water	Population	Total Distribution System Monitoring Locations
TTHM/ HAA5	SW and GWUDI (Subpart H)	< 500	2
		500 - 3,300	2
		3,301 - 9,999	
		10,000 - 49,000	4
		50,000 - 249,999	8
		250,000 - 999,999	12
		1,000,000 - 4,999,999	16
		≥ 5,000,000	20
	Ground water	< 500	2
		500-9,999	
		10,000-99,999	4
		100,000-499,999	6
		≥ 5,000,000	8

UCMR4 Chemistry Analytes



Metals: EPA Method 200.8, ASTM D5673-10, SM 3125

Contaminant	MRL (ug/L)	Additional Information
germanium	0.3	Naturally-occurring element;
manganese	0.4	Naturally-occurring element;

Pesticides and a Pesticide Manufacturing Byproduct: EPA Method 525.3

Contaminant	MRL (ug/L)	Additional Information
alpha-hexachlorocyclohexane	0.01	Component of benzene hexachloride (BHC); formerly used as an insecticide
chlorpyrifos	0.03	Organophosphate; used as an insecticide, acaricide and miticide
dimethipin	0.2	Used as an herbicide and plant growth regulator
ethoprop	0.03	Used as an insecticide
oxyfluorfen	0.05	Used as an herbicide
profenofos	0.3	Used as an insecticide and acaricide
tebuconazole	0.2	Used as a fungicide
total permethrin (cis- & trans-)	0.04	Used as an insecticide
tribufos	0.07	Used as an insecticide and cotton defoliant

Alcohols: EPA Method 541

Contaminant	MRL (ug/L)	Additional Information
1-butanol	2.0	Used as a solvent, food additive and in production of other chemicals
2-methoxyethanol	0.4	Used in a number of consumer products, such as synthetic cosmetics,
2-propen-1-ol	0.5	Used in the production flavorings, perfumes and other chemicals

Semivolatile Chemicals: EPA Method 530

Contaminant	MRL (ug/L)	Additional Information
butylated hydroxyanisole	0.03	Food Additive/Anti oxidant
o-toluidine	0.007	Production of dyes, etc.
quinoline	0.02	Pharmaceutical, flavoring agent, component of coal

UCMR4 DBPs




HAA Groups (EPA Method 552.3 or 557)			
dichloroacetic acid (DCAA)	HAA5		HAA9
monochloroacetic acid (MCAA)			
trichloroacetic acid (TCAA)			
monobromoacetic acid (MBAA)			
dibromoacetic acid (DBAA)			
bromochloroacetic acid (BCAA)	HAA6Br		
bromodichloroacetic acid (BDCAA)			
chlorodibromoacetic acid (CDBAA)			
tribromoacetic acid (TBAA)			

UCMR4 Algal Toxins



Contaminant	MRL ($\mu\text{g/L}$)	Method
“total microcystins”	0.3	EPA 546
microcystin-LA	0.008	EPA 544
microcystin-LF	0.006	EPA 544
microcystin-LR	0.02	EPA 544
microcystin-LY	0.009	EPA 544
microcystin-RR	0.006	EPA 544
microcystin-YR	0.02	EPA 544
nodularin	0.005	EPA 544
anatoxin-a	0.03	EPA 545
cylindrospermopsin	0.09	EPA 545

UCMR4 Algal Toxin “Trigger”



UCMR4 Data Elements



Utility Data Entry		Lab Data Entry		
Public Water System Identification (PWSID) Code	Sampling Point Identification Code	Sample Collection Date	Analysis Batch Identification Code	Laboratory Identification Code
Public Water System Name	Sampling Point Name	Sample Identification Code	Analysis Date	Sample Event Code
Public Water System Facility Identification Code	Sampling Point Type Code	Contaminant	Sample Analysis Type	Bloom Occurrence
Public Water System Facility Name	Disinfectant Type	Analytical Method Code	Analytical Results-Sign	Indicator of Possible Bloom – Treatment
Public Water System Facility Type	Treatment Information	Extraction Batch Identification Code	Analytical Result-Measured Value	Cyanotoxin Occurrence
Water Source Type	Disinfectant Residual Type	Extraction Date	Additional Value (for spikes)	Indicator of Possible Bloom – Source Water Quality Parameters

UCMR4 CDX SET UP STEPS



1. CDX Account
2. SDWARS4
3. Profile Settings
4. Notification Letter
5. Add Contacts
6. Add Inventory
7. Confirm Schedule
8. Add Zip Codes
9. Notimate User
10. Confirm & Save

STEP 1 – CDX ACCOUNT



Log in to CDX

User ID

Password

Log In **Register with CDX**

Forgot your Password?
Forgot your User ID?
Warning Notice and Privacy Policy

<https://cdx.epa.gov/>

STEP 2 – SDWARS4



EPA United States Environmental Protection Agency

Home About Recent Announcements Terms and Conditions FAQ Help

CDX Central Data Exchange Contact Us
Logged in as (Log out)

MyCDX Inbox My Profile Submission History

Services		OC Manage
Status	Program Service Name	Role
	UCMR4: Unregulated Contaminants Monitoring Rule 4	SDWARS4

[Add Program Service](#) [Manage Your Program Services](#)

CDX Service Availability
[See the status for all program services](#)

News and Updates
No news/updates.

STEP 3 – PROFILE SETTINGS



Application Profile Settings

Organization Name

PWS Name


Program Client ID

PWS Identification Number

Program

UCMR4

Proceed Cancel



STEP 4 – NOTIFICATION LETTER



Notification Letter

NOTIFICATION LETTER
January 3, 2017

A PWS user must accept the notification letter.

RE: Unregulated Contaminant Monitoring for Surface Water (SW) and Ground Water Under the Direct Influence of Surface Water (GWUDI) Systems Serving over 10,000 Persons

Dear Public Water System:

The purpose of this letter is to notify your public water system (PWS) of its monitoring requirements under the revision to the Unregulated Contaminant Monitoring Rule (UCMR4). The U.S. Environmental Protection Agency (EPA) published the final rule detailing the upcoming monitoring of unregulated contaminants at PWSs on December 20, 2016, establishing a new list of contaminants to be monitored and the conditions for that monitoring. This rule benefits public health by providing EPA and other interested parties with scientifically valid data on the national occurrence of selected contaminants in drinking water. This dataset is one of the primary sources of information on occurrence, levels of exposure and population exposure EPA uses to develop regulatory decisions for contaminants in the public drinking water supply.

Under the UCMR4, all community water systems and non-transient, non-community water systems serving more than 10,000 persons must participate in Assessment Monitoring (AM). Our records indicate that your surface water system must monitor for all List 1 contaminants: metals, pesticides, semi-volatile organic chemicals (SOCs), alcohols (AM 1), haloacetic acids (HAAs) (AM 2), and cyanotoxins (AM 3).

What must your PWS complete in SDWARS before December 31, 2017?
Similar to reporting under UCMR3, PWSs will use the Central Data Exchange (CDX) (<https://cdx.epa.gov/>) to access the updated version of the Safe Drinking Water Assessment and Review System (SDWARS4). PWSs are required to:

- enter your official and technical contact information;
- review and, if necessary, update your sample location data by adding missing locations (e.g., Stage 1 and Stage 2 Disinfectants and Disinfection Byproduct Rules sampling locations for the HAAs), indicating ineligible locations or editing basic information about the locations; and
- review and, if you wish, revise your monitoring schedule assigned by the EPA.

What must your PWS do during UCMR4 monitoring?
Your PWS must ensure that samples are properly collected, packaged and shipped to a UCMR4 EPA approved laboratory. Your PWS is also responsible for providing the data elements required for each sampling location (e.g., disinfection type, treatment type etc.) in SDWARS. Once data are posted to SDWARS by your laboratory, your PWS will have 60 days to review and act upon these results. If you choose not to review these results in this time frame, they will be considered final. Additionally, community water systems are required to address their UCMR monitoring results in their annual Consumer Confidence Report (CCR) whenever unregulated contaminants are detected (<https://www.epa.gov/ccr>).

Where can I find more information about UCMR4?
EPA recommends that you review the complete rule and supporting reference materials addressing UCMR4 at <https://www.epa.gov/dwucmr/fourth-unregulated-contaminant-monitoring-rule>.

- The "Revisions to the Unregulated Contaminant Monitoring Rule (UCMR4) for Public Water Systems and Announcement of Public Meeting" [EPA-HQ-OW-2015-0218; FRL-9956-71-OW];
- UCMR4 Implementation fact sheets: Metals, Pesticides, SOCs, and Alcohols (AM 1), Haloacetic Acids (HAAs) (AM 2), Cyanotoxins (AM 3) and General Information;
- EPA approved laboratories for UCMR4 (the list will be updated as additional laboratories are approved);
- Outreach materials and announcements for stakeholder meetings and trainings.

Analytical results from UCMR are publicly available in the National Contaminant Occurrence Database (NCOD); for a summary of the NCOD results, tips for querying NCOD, and health effects information please refer to the UCMR Data Summary document.

This notification letter is being sent to you as the official representative of this PWS. If someone else at your PWS needs this information, such as the plant operator, please provide them with a copy of this letter. Your cooperation in meeting these requirements is appreciated.

For questions regarding SDWARS or CDX, please contact the CDX Help Desk at 1-888-890-1995. For Implementation or general questions, please contact the UCMR Message Center at 1-800-949-1561 or 1UCMR4@epa.gov. Thank you for your cooperation.



STEP 5 – ADD CONTACTS



MyCDX » PWS Home » Contacts

PWS Contacts

All PWSs must have an "Official" contact defined as the administrative representative for the PWS and a "Technical" contact that may be contacted as an alternate representative. Specify additional contacts as "Other" contact types. Edit or delete these contacts using the appropriate links any time you experience changes in personnel. Click Add Contact to include a contact. Click the edit icon to revise the information for that contact. Click the delete icon to remove that contact.

You must assign a Technical and Official contact immediately. If you have just deleted either of these, you must add a new contact to comply with UCMRA. You cannot proceed in SOWARS until you assign a Technical and Official contact.

[Add Contact](#)

Contact Name	Contact Email	Affiliation/Organization	Contact Type	Actions
No Contacts found for this PWS.				

SOWARS Version: 4, Release 2.0
(04/2015, 1/12)

OFFICIAL & TECHNICAL CONTACTS



Add PWS Contact

i You must complete every field marked with an *. All contact information is confidential and is only available to regulatory authorities. You must click **Save Changes** for the information to be added to the database. Use the **Receive Auto Email Notification(s)** checkbox(es) if you wish to receive email messages reminding you about certain critical tasks.

First Name*

Last Name*

Contact Type*

Affiliation / Organization*

Mailing Address 1

Mailing Address 2

City

State

Zip Code

Phone* ext.

Email*

Receive Auto Email Notification(s)

- Scheduling Reminders
- Lab Posted Data Notifications
- Any Missing Additional Data Notifications

(33-PWS-1102a)

Add PWS Contact

i You must complete every field marked with an *. All contact information is confidential and is only available to regulatory authorities. You must click **Save Changes** for the information to be added to the database. Use the **Receive Auto Email Notification(s)** checkbox(es) if you wish to receive email messages reminding you about certain critical tasks.

First Name*

Last Name*

Contact Type*

Affiliation / Organization*

Mailing Address 1

Mailing Address 2

City

State

Zip Code

Phone* ext.

Email*

Receive Auto Email Notification(s)

- Scheduling Reminders
- Lab Posted Data Notifications
- Any Missing Additional Data Notifications

(33-PWS-1102a)

CONFIRM CONTACTS





✓ Contact has been added.



MyCDX > PWS Home > Contacts

PWS Contacts

i All PWSs must have an "Official" contact defined as the administrative representative for the PWS and a "Technical" contact that may be contacted as an alternate representative. Specify additional contacts as "Other" contact types. Edit or delete these contacts using the appropriate links any time you experience changes in personnel. Click **Add Contact** to include a contact. Click the **edit** icon to revise the information for that contact. Click the **delete** icon to remove that contact.

You must assign a Technical and Official contact immediately. If you have just deleted either of these, you must add a new contact to comply with UICMR4. You cannot proceed in SOWARS until you assign a Technical and Official contact.

Add Contact  

Contact Name	Contact Email	Affiliation/Organization	Contact Type	Actions
Howard The Duck	howard.duck@marvel.universe.org	Marvel Universe	Official	 

MyCDX

SOWARS Version: 4, Release 2.0
(© S. PWS, 11/02)

STEP 6 – ADD INVENTORY



MyCOX > PWS Home > PWS Inventory

Designate and Review Your Inventory

i If you wish to load your inventory from SDWARSS, click **Upload/Import Inventory** drop-down and select **Import Inventory from SDWARSS**. You will be able to select which locations will get loaded. Select the 'Yes' under **Sampling Required** to identify applicable sample locations for UCMRA monitoring. If you select 'No' under **Sampling Required**, you will be required to provide a reason. Click either the **Facility ID** or **Sample Point ID** to edit the inventory you specified. Click **Add Facility** or **Add SP to Existing Facility** to add inventory. You must click **Save Changes** for the information to be added to the database. (more...)

Note: Please ensure all required sample locations for UCMRA are included in your inventory below. This includes all entry points to the distribution system and for those PWSs monitoring HAA5, their Stage 2 Disinfectants and Disinfection Byproducts Rule distribution system sites and intake(s) prior to treatment. An intake sample is not required for a consecutive connection (100% purchased).

Add Facility

No facilities or sample points have been added.

Upload/Import Inventory

- Upload Facilities & Sample Points
- Import Inventory from SDWARSS

SDWARSS Version: 4, Release 3.0
(©S PWS 1103)

MANUAL OR IMPORT



Create a New Facility and Sample Point

i You must complete every field marked with an (*). You must click Save Changes for the information to be added to the database.

Facility ID*

Facility Name*

Facility Type*

Water Type*

Sample Point ID*

Sample Point Name*

Sample Point Type - Select Facility Type -

© 2014 PWS 1026x

Logged in as [redacted]

EPA United States Environmental Protection Agency

CDX

MyCDX - PWS Reporting - Upload Facilities & Sample Points

Upload Facilities & Sample Points

i Click for help with the file structure

No file chosen

© 2014 PWS Version 3 Release 1.1
© 2014 PWS 1026x

Logged in as [redacted]

- PWS
- Contacts
- Inventory
- Schedule
- Zip Code
- Numbers Live

IMPORT FROM SDWARS3



Import Facilities and Sample Points from SDWARS3

i Select the sample locations from SDWARS3 which need to be loaded into SDWARS4. You must click **Next >** button to review your inventory before it is added to the database.

Select All <input type="checkbox"/>	Facility ID	Facility Name	Facility Type	Water Type	Sample Point ID	Sample Point Name	Sample Point Type
<input type="checkbox"/>	00001	Treatment Plant #1	TP	GW	EP001	EP from TP #1	EP
<input type="checkbox"/>	00002	Treatment Plant #2	TP	GW	EP002	EP from TP #2	EP

SS.PWS.110M

Next >

Cancel

Import Facilities and Sample Points from SDWARS3

i Select the **Import** button to add the inventory to the database.

Facility ID	Facility Name	Facility Type	Water Type	Sample Point ID	Sample Point Name	Sample Point Type
00001	Treatment Plant #1	TP	GW	EP001	EP from TP #1	EP
00002	Treatment Plant #2	TP	GW	EP002	EP from TP #2	EP

SS.PWS.110g

Back

Import

Cancel

MANUALLY ADD



Create a New Facility and Sample Point

i You must complete every field marked with an (*). You must click **Save Changes** for the information to be added to the database.

Facility ID*

Facility Name*

Facility Type*

Water Type*

Sample Point ID*

Sample Point Name*

Sample Point Type - Select Facility Type -

Save Changes **Cancel**

(SS.PWS.1103a)

Add Sample Point to Your Facility

i You must complete every field marked with an (*).

Select an existing Facility to which the sample point (SP) will be added. If the facility you are looking for is not listed, you must create it by clicking **Add Facility** link on the previous page.

You must click **Save Changes** for the information to be added to the database.

Facility*

Sample Point ID*

Sample Point Name*

Sample Point Type - Select Facility -

Save Changes **Cancel**

(SS.PWS.1103c)

STEP 7 – CONFIRM SCHEDULE



EPA United States Environmental Protection Agency

MyCDX > PWS Home > PWS Schedule > AM1

Review Your Schedule

Click the date specified for Sample Event 1 (SE1) if you wish to edit the sample schedule for the corresponding location. (For groundwater sample points, the second sampling may occur within 5-7 months from the original sampling. Surface water systems must sample every 3 months.)

Filter by...

Facility ID: Facility Name: Facility Type: Water Type:

Sample Point ID: Sample Point Name:

Monitoring Requirement: AM1

Facility ID: 00001 Facility Name: Treatment Plant #1 Facility Type: TP Water Type: GW

Sample Point ID	Sample Point Name	Sample Point Type	SE1	SE2	SE3	SE4
EP001	EP from TP #1	EP	Jan 2018	Jul 2018		

Facility ID: 00002 Facility Name: Treatment Plant #2 Facility Type: TP Water Type: GW

Sample Point ID	Sample Point Name	Sample Point Type	SE1	SE2	SE3	SE4
EP002	EP from TP #2	EP	Jan 2018	Jul 2018		

Review Schedule ↑

Review Schedule ↑

STEP 8 – ADD ZIP CODES



EPA United States Environmental Protection Agency

MyCDIX > PWS Home > Zip Codes

Zip Codes

Click Add Zip Codes to add a zip code(s). Click Delete Zip Codes to remove one or more selected zip codes.

Add Zip Codes

Zip Code
No zip codes have been added.

Add PWS Zip Codes

You can copy/paste a comprehensive list of zip codes within the zip code field. A zip code MUST be a five digit number. You must click Save Changes for the zip code(s) to be added to the database.

Zip Code(s):*

Zip codes can be copy/pasted or typed

(33.PWS.1105a)

Save Changes Close

STEP 9 – NOMINATE USER



EPA United States Environmental Protection Agency

MyCDX > PWS Home > Nominate PWS User

Nominate a PWS User

You must complete every field marked with an *. You must click Nominate to generate a CRX.

First Name*

Last Name*

Organization Name*

Registrant's Work Mailing Address 1*

Registrant's Work Mailing Address 2

City*

State*

Zip Code*

Phone*

Email*

Terms and Conditions

By nominating this individual, the nominator agrees to the following:

- As an authorized representative of the public water system (PWS), I am nominating another individual to receive and/or report Unregulated Contaminant Monitoring Rule (UCMR) data as required under the 1996 Amendments to the Safe Drinking Water Act and specified in 40CFR 141.26
- I authorize the nominee to report UCMR information for the PWS.
- I affirm that the nominee has a legitimate business affiliation with the PWS.
- I understand that by nominating this user, I accept full responsibility for their actions while engaging the Federal Safe Drinking Water Act review and Review System (SDWAARS). I further understand that the system will be able to associate nominees with the nominator.
- I agree to print and present the CRX to the nominee and verify that they fully understand the TERMS AND CONDITIONS.
- I understand that the nominee will have the right to nominate additional Representatives for the PWS.
- I agree to notify the Central Data Exchange (CDX) within ten working days if the status of the nominee changes, and they no longer need to interact with CDX on behalf of the PWS. I agree to make the notification via either the CDX web interface or by notifying the CDX Technical Support staff at 1-888-895-1995. This notification allows CDX to deactivate the designated account and protect it from potential abuse.

Warning Notice

The CDX registration procedure is part of a United States Environmental Protection Agency (EPA) computer system, which is for authorized use only. Unauthorized access or use of this computer system may subject violators to criminal, civil, and/or administrative action. All information on this computer system may be monitored, recorded, read, copied, and disclosed by and to authorized personnel for official purposes, including law enforcement. Access or use of this computer system by any person, whether authorized or unauthorized, constitutes consent to these terms.

Privacy Statement

EPA will use the personal identifying information that you provide for the expressed purpose of registration to the Central Data Exchange site and for updating and correcting information in external EPA databases as necessary. EPA will not make this information available for other purposes unless required by law. EPA does not sell or otherwise transfer personal information to an outside third party. (Federal Register, March 15, 2002, Volume 67, Number 52)(Page 12915, CDX 1)

Nominate

STEP 10 – CONFIRM & SAVE



Facility ID: 91821 Facility Name: Oliver P. Roemer Facility Type: IN Water Type: SW										
Sample Point ID	Sample Point Name	Sample Point Type	SEH1	SEH2	SEH3	SEH4				
3610004051	State Project Water	SR	Jan 2018	May 2019	Apr 2018	Aug 2019	Jul 2018	Nov 2019	Oct 2018	Feb 2020

Facility ID: 91801 Facility Name: Well 54 Facility Type: TP Water Type: GW							
Sample Point ID	Sample Point Name	Sample Point Type	SEA1	SEA2	SEA3	SEA4	
3610004045	EP #46 - Well 54	EP	Jan 2018	May 2019	Jul 2018	Nov 2019	

Facility ID: 91813 Facility Name: 213 E. Walnut Facility Type: DS Water Type: MX										
Sample Point ID	Sample Point Name	Sample Point Type	SEH1	SEH2	SEH3	SEH4				
3610004601	213 E. Walnut	DS	Jan 2018	May 2019	Apr 2018	Aug 2019	Jul 2018	Nov 2019	Oct 2018	Feb 2020

UCMR4 Key Dates



Key UCMR4 Dates

Jan. 19, 2017	UCMR4 Effective Date
Jan. 23, 2017	1 st Proficiency Test Sample issued
Feb. 21, 2017	Laboratory Approval Registration Deadline
April 12, 2017	EPA UCMR4 Webinar
April 19, 2017	Laboratory Approval Application Packages Deadline
April 19, 2017	Groundwater Representative Monitoring Plan Deadline
Aug–Sept, 2017	Last Proficiency Test Sample issued
Dec. 31, 2017	Sample Inventory Location & Schedule Updates Deadline
Jan. 1, 2018	Monitoring Commences
Dec. 31, 2020	Monitoring Concludes

Now
10-31-17

April 19, 2017

UCMR4 Key Contacts



UCMR4_Sampling_Coordinator@epa.gov

**Jake Jenzen
EPA Region 9
415-972-3570
Jenzen.Jacob@epa.gov**

**Rick Zimmer
SDWA Committee Chairperson
949-466-8266
RickZimmer@eurofinsus.com**

Speaker #7

Principles of Efficient Water Well Design

Kevin McGillicuddy

Roscoe Moss Company

kmc@roscoemoss.com



Efficient Water Well Design and Construction

Designing for Optimum Strength and Efficiency



Water Replenishment District of Southern California

August 9, 2017


Kevin McGillicuddy, P.G.
Roscoe Moss Company

Key To Efficient Well Design

- Goal to construct well capable of producing the maximum rate with the least amount of drawdown and at the lowest energy cost

Well Efficiency

Aquifer Loss
Total drawdown



Cornerstones of Efficient Well Design



**Durable Casing
and Screen**



**Proper Gravel
Pack Design**



**Proper Screen
Slot Size**



**Thorough Well
Development**

Critical Components in Designing Efficient Gravel Envelope Wells - **Steel Casing and Screen**

- Select steel type for the casing and screen that maximizes the working life of the well
- Specify casing and screen wall thickness that:
 - meets physical requirements during construction
 - and*
 - has capability of withstanding rigorous physical development and rehab methods as the well matures

Commonly Used Steels

Non – Corrosion Resistant

- Mild / Low-Carbon Steel

Corrosion Resistant Steels

- Copper-Bearing
- High-Strength Low-Alloy (ASTM A606 Type 4)
- Stainless – Types 304 and 316L




Durability and Cost

Steel Type	Metal Loss*	Corrosion Resistance*	Cost Factor
Low Carbon	2.8794 mills/yr	1X	1.0X
0.2% Copper	0.7438 mills/yr	4X	1.6X
HSLA	0.3131 mills/yr	9X	1.9X
SS Type 304	0.0118 mills/yr	244X	4X

* *Source: GEOSCIENCE Support Services, 1999*

Downhole video of El Paso well constructed in 1955






Gravel Pack Selection

- Begin with properly collected formation samples at the drilling site
- Conduct sieve analysis to determine Formation Gradation
- Select Gravel Pack gradation using a multiplier on the Formation Gradation



Determine Gradation of Aquifer Sediments



Gravel Pack Selection

6X larger than
smallest 30% of
Formation

Filter Pack

Aquifer



Gravel/Filter Packs Comparison



#4 (4.8mm)



#6 (3.4mm)



#8 (2.4mm)



#12 (1.7mm)



#20 (0.8mm)



#30 (0.6mm)



#16 (1.2mm)

High Silica Content

Well Rounded

Uniform Grain Size

Slot Size Selection

- **Primary function of screen slot is to stabilize the gravel envelope, *not the formation!***
- Sized to pass 10 to 20% gravel pack (retain 90 to 80%)
- Slot size more critical than % open area

Slot Size Selection

- **Use the largest, reasonable slot size**
 - Provides best opportunity for distributing energy required for initial development and future redevelopment / rehabilitation procedures



Well Development

Any process used to improve permeability of an aquifer and repair drilling damage.

Accomplished by removing fines through the gravel pack and well screen.

Must be aggressive and directed.

Must be repeated at regular intervals throughout the life of the well

Phases of Well Development

Pre-development : Controlling drilling fluids during drilling and construction

Preliminary development : swabbing, jetting, flushing, airlifting, and bailing

Final development : pumping, surging, and backwashing

Repair Drilling Damage



Wall Cake

Filter Pack

Aquifer

Dual Swab Development





Figure 14.2. Double-flanged swab without bypass.




Dual Swab and Simultaneous Airlift

- The well is mechanically swabbed by raising and dropping the drill pipe equipped with a tight fitting dual swab on the bottom.
- During swabbing, water is airlifted from the well.
- Swabbing is started at the top of the screen to minimize the risk of sand locking the swabs.



Measuring Sand Content using Rossum Sand Tester





Properly Designed Gravel Envelope & Screen Slot Size

Well Screen

Filter Pack

Aquifer



SUMMARY

- Corrosion resistant steels have proven effective in extending well life
- Steel and material selection must consider corrosion prevention, potential aggressive well development and rehabilitation procedures
- Life Cycle Cost Analysis demonstrates that payback period for stainless steel is relatively short, 7 – 8 yrs

SUMMARY

- Select appropriate gravel pack gradation to stabilize formation
- Select appropriate slot size to stabilize/retain gravel pack
- Employ rigorous and thorough well development methods
- Monitor the specific capacity and efficiency of the well to determine when rehab is needed and minimize operational costs

Questions?



Kevin McGillicuddy, P.G.

(323) 263-4111

Email:

kmc@roscoemoss.com

Website:

www.roscoemoss.com



Speaker #8

Groundwater Basin Master Plan

Everett Ferguson

Water Replenishment District

eferguson@wrd.org






WATER REPLENISHMENT DISTRICT
OF SOUTHERN CALIFORNIA


Groundwater Basins Master Plan

Central Basin and West Coast Basin

Everett Ferguson, Senior Hydrogeologist



- **Central Basin Groundwater Pumpers**
- **West Coast Basin Groundwater Pumpers**
- **City of Los Angeles DWP and Sanitation**
- **County Sanitation Districts of LA County**
- **West Basin Municipal Water District**
- **Metropolitan Water District of Southern California**
- **CH2M and RMC**



420 square miles

43 cities

Population = 4 million


West Coast Basin *Central Basin*
(over 10% of California's population)

Coast Basin

Groundwater provides up to
281,000 AFY
of the total water supply



Over 400 Wells Provide Water Supply





Past History:

1900s-1950s

Pumping Double Natural
Replenishment.

OVERDRAFT



**100 foot
drop in
10 years
(10'/yr)**

- **Plunging Water Levels**
- **Loss of Supply**
- **Wells going Dry**
- **Seawater Intrusion**

Solutions...

- 1) WRD formed in 1959 to provide managed aquifer recharge to eliminate overdraft.**
- 2) Pumping adjudicated at 281,835 acre feet/year. Higher than natural recharge, but WRD makes up the difference.**
- 3) LA County installed 16 miles of wells along the coast to stop seawater intrusion. WRD buys the imported and recycled water used for injection.**


Spreading (infiltration) Basins

West Coast Barrier




Spreading Grounds


Dominguez Gap Barrier



Alamitos Barrier



LA County Public Works Recharge Facilities



Injection Wells



Spreading Grounds





Injection Wells



Spreading Grounds



RESULTS of Groundwater Management ...



... Rising Water
Levels, Drought
Protection,
Seawater
Intrusion
Protection

No


- Continued challenges to balance pumping with groundwater replenishment programs in a cost-effective and reliable manner.
- 2016 WRD completed a Groundwater Basins Master Plan as a roadmap to maximize sustainable groundwater pumping and reduce reliance on imported water.




Why A Master Plan For Adjudicated Basins?

- **Pumping in both basins currently below adjudicated limits. Unnecessary purchases of imported water when groundwater could be used.**
- **Recent Judgment amendments to adjudications allow for storage projects for the first time. Need to evaluate alternatives.**
- **Opportunities to replace nearly all imported water demands with groundwater if new recharge facilities and replenishment supplies can be found to offset the increase in pumping.**


**TODAY
(through 2018)**



**MAXIMIZE
ADJUDICATED
PUMPING
(2018-2028)**



**UTILIZE
GROUNDWATER
STORAGE
(2028-2038)**



**Adjudicated
Limit**

WRD's Goals

- **Maximize local water supplies.**
- **Reduce reliance on imported water.**
- **Increase water supply sustainability and reliability.**
- **Mitigate future cost increases of water.**
- **Partner with local water reclamation agencies to create new sources of water.**





Phased approach

- Phase 1 – Interviews with basin stakeholders and identification of alternative management scenarios.
- Phase 2 – Detailed analysis of basin alternatives, including model runs and cost evaluations.
- Programmatic Environmental Impact Report.




The Groundwater Model Used for Analysis

- Built by USGS using Modflow Groundwater Code.
- Based on extensive hydrogeologic data collection.
- 4 model layers represent major aquifer systems.
- 1/2 mile grids, 67 rows, 70 columns (18,760 model cells).
- 30-Year Calibration Period.
- Well Documented USGS Report (03-4065).



Groundwater Basins Master Plan Concepts




Notes:

CB = Central Basin
 MFB = Montebello Forebay

LAFB = Los Angeles Forebay
 WCB = West Coast Basin

West Coast Basin – Inland Injection



Central Basin – Los Coyotes WRP



Central Basin – Los Angeles Forebay



Central Basin – Concept B2
103,250 New Replenishment Supply
320,600 Pumping

New AWT
45,480 New (Inject)

Stormwater
17,000 New

SJC/WN/Pomona
 50,000 Existing
 21,000 GRIP
27,580 New (MMSG)
8,690 New (Inject)
 98,580 Total

Los Coyotes
 0 Existing
9,500 New (Inject)

Stormwater
5,000 New

LVL AWTF
 8,000 Existing





FIGURE 3-19
 Los Angeles River Aquifer Recharge and Recovery Facility




West Coast Basin – Concept B
30,000 New Replenishment Supply
94,500 Pumping
 Existing pumping patterns

WBMWD ECL
 17,000 Existing
 15,500 New (A)
 7,500 New (B)
 40,000 Total

CSDLAC
 17,000 New (B)
 17,000 Total

LADWP TITP
 5,000 Existing
 2,500 New (A)
 5,500 New (B)
 13,000 Total



West Coast Basin Yield vs. Costs



Annual Yield and Present Value Unit Cost for the West Coast Basin Alternatives




Figure ES-7. Annual Yield and Present Value Unit Cost for the West Coast Basin Alternatives

Central Basin Yield vs. Costs





Figure ES-8. Annual Yield and Present Value Unit Cost for the Central Basin Alternatives

- **Groundwater Basins Master Plan developed as a roadmap to identify ways to increase groundwater pumping that is balanced by increased groundwater recharge.**
- **Provides Central and West Coast Basin stakeholders with options and costs to replace imported supplies with sustainable groundwater pumping.**
- **Next phase is for WRD to work with groundwater producers to facilitate development of projects identified in the Plan.**



WATER REPLENISHMENT DISTRICT
OF SOUTHERN CALIFORNIA

Thank You





For more information visit www.wrd.org