



**RESPONSES TO QUESTIONS RELATING TO THE
REQUEST FOR PROPOSALS FOR
FOR PROFESSIONAL SERVICES FOR WELL PROFILING FOR THE WRD WELL PROFILING PROGRAM (RFP-17-007)**

Updated as of December 13, 2017

<http://www.wrd.org/business/water-replenishment-business.php>

Below are responses to questions that have been asked during this Request for Proposals (RFP) process. This question and response table will be updated periodically with other questions that may be asked during this RFP process. The deadline for questions regarding this RFP will be on Wednesday, December 13, 2017 at 12:00PM PDT.

QUESTION	RESPONSE
<p>1. With regard to Task 2, Video Log Well, if the well(s) has(have) an existing pump is there a camera tube to accommodate the video camera or will the pump need to be pulled?</p>	<p>This Well Profiling Service is for existing wells with an existing pump. As indicated in the second paragraph of the RFP Background Section:</p> <p>“The well profiling method preferred by WRD is the United States Geological Survey well-bore flow and depth-dependent sample collection method (Appendix A) because the profiling can be performed using the existing pumping equipment thereby avoiding the time and expense of removing the pump. However, firms responding to this RFP may propose alternate methods if they choose.”</p> <p>The wells to be profiled have not been identified but most wells have a camera tube to accommodate the video camera and the equipment for flow profiling and depth-dependent sampling. See Appendix A of the RFP.</p>
<p>2. Part IV (Proposal Requirements), number 13, states that “Five (3) hard copies and one (1) electronic copy of the proposal must be received...”. Please clarify the number of hard copies (five or three) that are required for this submittal.</p>	<p>Three hard copies.</p>